



AWWA recommended intervals for positive displacement and multijet type meters are:

- 5/8" size(s) - 10 years
- 3/4" size - 8 years
- 1" size - 6 years
- 1 1/2" size - 4 years
- 2" size - 4 years

Recommended intervals for 2" to 8" turbine meters - please check with local water authorities for requirements.