

SSM® SERIES METERS

NSF / ANSI 61 Annex G & 372



The SSM® series have stainless steel meter bodies, tested and certified to NSF/ANSI 61 Annex G & 372 for lead-free compliance and meet or exceed AWWA C708 specifications. The SSM® multi-jet series meters have a long meter life and good tolerance to contaminants. The series is well suited for industrial, commercial and residential applications. The dry sealed registers are easy to read and will retain their clear view display. The SSM® series meter is available in sizes from $\frac{5}{8}$ " x $\frac{1}{2}$ " to 2" with maximum flow rates up to 160 GPM and pressures up to 150 psi. Registrations are available in gallons, liters or cubic feet.

The SSM® meter is a totalizing multi-jet meter for those applications that only need to read the totalized flow at the meter. The SSMRS® meter is equipped with a reed switch for a dry contact pulse output and the SSMR® meter includes a reed switch for a dry contact pulse output and our A31UR Universal Remote® counter.



1710 EATON DRIVE • GRAND HAVEN, MICHIGAN 49417

PHONE (616) 842-0420E-

MAIL CARLON@CARLONMETER.COM • WEBSITE WWW.CARLONMETER.COM

METER SELECTION CHART

METER / PIPE SIZE	MODEL	*CONTINUOUS FLOW	FLOW RANGE	WEIGHT	LENGTH	HEIGHT	WIDTH	CONNECTION LENGTH (X2)
5/8" X 1/2"	625SSM	8 GPM	1/4 - 20 GPM	3.3 lbs.	7 1/2"	4 1/4"	3 5/8"	2"
5/8" X 3/4"	6251SSM	10 GPM	1/4 - 20 GPM	3.3 lbs.	7 1/2"	4 1/4"	3 5/8"	2"
3/4" X 3/4"	750SSM	15 GPM	1/2 - 30 GPM	3.4 lbs.	7 1/2"	4 5/8"	3 7/8"	2"
1"	1000SSM	25 GPM	3/4 - 50 GPM	5.7 lbs.	10 1/4"	4 5/8"	3 7/8"	2 1/4"
1 1/2"	150SSM	50 GPM	2 - 100 GPM	10.6 lbs.	11 7/8"	5 1/2"	4 7/8"	2 1/2"
2"	200SSM	80 GPM	2 - 160 GPM	13 lbs.	11 7/8"	5 1/2"	4 7/8"	2 3/4"

***Continuous Flow:** The size of meter selected should be based upon continuous flow, GPM, as opposed to pipe size. For example, if it is determined that continuous flow is 25 GPM, a 1" meter should be selected rather than a 3/4" meter.

ORDERING INFORMATION: Select the meter model number from the Meter Selection Chart above.

Add a **G** for Gallon reading or a **C** for Cubic Feet reading or an **L** for Liters reading.

Example: 1 1/2" Meter with Cubic Feet register = 150SSM-C.

X = AVAILABLE CONTACT SETTINGS

(All contact settings are pre-set at the factory to your specification)

GPC = Gallons Per Contact • LPC = Liters Per Contact • CFPC = Cubic Feet Per Contact

METER / PIPE SIZE	MODEL	0.1 GPC	1 GPC	10 GPC	100 GPC	.01 CFPC	0.1 CFPC	1 CFPC	10 CFPC	1 LPC	10 LPC	100 LPC	1000 LPC
5/8" X 1/2"	625SSMRS	X	X	X	X	X	X	X	X	X	X	X	X
5/8" X 3/4"	6251SSMRS	X	X	X	X	X	X	X	X	X	X	X	X
3/4" X 3/4"	750SSMRS	X	X	X	X	N/A	X	X	X	X	X	X	X
1"	1000SSMRS	X	X	X	X	N/A	X	X	X	X	X	X	X
1 1/2"	150SSMRS	N/A	X	X	X	N/A	X	X	X	X	X	X	X
2"	200SSMRS	N/A	X	X	X	N/A	X	X	X	X	X	X	X

SSM® METER SPECIFICATIONS

Reed Switch:	Dry contact type, normally open, 24V, 10mA maximum
Pressure Rating:	Maximum 150 psi.
Temperature Range:	35° - 122°F. Protect the meter from freezing.
PH Level Range:	6.5 – 8.0
Accuracy:	+/- 1.5% of maximum flow when operating between minimum and maximum flow range.
Register Options:	U.S. Gallons, Cubic Feet and Liters

Installation Instructions:

1. Flush the line thoroughly after all plumbing changes to prevent contaminants from entering the meter.
2. Install horizontally with the register facing up and inlet port facing the water supply line.
3. For outdoor installation, protect meter from direct exposure to the elements.
4. Protect meter from backflow of water opposite of indicated flow direction.

Helpful Hints:

1. All values used in a water line need to be operated slowly, and all electrically actuated valves should be slow closing. This will eliminate possible meter damage from water hammer in your system. Carlon offers an excellent slow closing ball valve (SCBV).
2. Install a strainer upstream of your water meter to protect the meter and any other in-line process equipment from becoming jammed by particulate matter.

Warranty: Carlon Meter, Inc. warrants its products to be free of defect in material or workmanship for a period of twelve months from the date of purchase. Contact us to obtain a copy of our complete statement of warranty.